

LOCATION 3045 Foxborough CT CITY GASTONIA

BETWEEN River Ridge Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	P	40'	6-5-95		
MAIN TO PROP. LINE	3/4'	P	0			
PROP. LINE TO BLDG.	3/4'	P	40'			

ENTERS: 3045 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 64' S of center of


Pressure Test: @ 100 psi For 1/4 Hrs. By S. HUFFORD

MAIN-SIZE 3/4' C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1995

DEPTH: 2 Ft. In. LOCATION 260' W. of center of River Ridge Dr.

"A" P/S READING 7 TOTAL ANODES 1# 0 17# 0 L.R. # 241224

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY