

LOCATION 502 FRANCIS ST CITY Gastonia  
BETWEEN WARD STREET & EDWARDS STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	66'	9-28-79		
MAIN TO PROP LINE	11	11	25'			
PROP LINE TO BLDG	11	11	41'			

ENTERS 502 BRANCHED INTO -  
TAP SIZE 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W C LOCATION 9' E. of COT

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SP Francis  
MAIN-SIZE 3" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1934  
DEPTH 2 FT 0 IN LOCATION \_\_\_\_\_

"A" P/S READING 1.20 TOTAL ANODES 1# - 17# - LR # \_\_\_\_\_

REMARKS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>PR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

