

LOCATION 516 Francis St CITY GASTONIA
BETWEEN Leroy Ave STREET & WARD Ave STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	96'	1/2" over 9/29/98		
MAIN TO PROP. LINE			24'			
PROP. LINE TO BLDG.			22'			

ENTERS: 516 BRANCHED INTO
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION South side of 516

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY DT
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998
DEPTH: 3 FT 0 IN LOCATION West side of Francis St

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 2038590

REMARKS Tied over 20' of Ex Plastic Service to new main
with 26' of 3/4" Plastic Pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY