

LOCATION 711 E Franklin Blvd CITY Gastonia
BETWEEN Avon STREET & Chestnut STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>2"</u>	<u>GFW</u>	<u>Welded ON Split fitting to</u>			
MAIN TO PROP LINE			<u>Remove AL 1400.</u>			
PROP LINE TO BLDG				<u>3-9-00</u>		

ENTERS _____ BRANCHED INTO _____
TAP SIZE _____ PRESSURE _____ PSI _____ INCHES W/C _____ LOCATION _____


PRESSURE TEST @ _____ PSI FOR _____ HRS BY _____

MAIN-SIZE _____ C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH _____ FT _____ IN _____ LOCATION _____

"A" P/S READING L.O TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS
Removed meter site. Had to weld ON
H17155 to stop line. It had NO cut off.
We also put 2" cut off ON Riser

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	