

LOCATION 739 E. Franklin Blvd. CITY GASTOWIA
BETWEEN Second Ave. STREET & Franklin Blvd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>18'</u>	<u>1-14-94</u>	<u>130' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 CW</u>	
PROP. LINE TO BLDG.						

ENTERS: 739 E. Franklin BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 100 P.S.I. _____ INCHES W.C. LOCATION 143' S of C of Franklin Blvd.

PRESSURE TEST: @ 100 psi For 14 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993


DEPTH: 3 Ft. 0 In. LOCATION 20' W of C of Chestnut St.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

Retired & Renewed Service.

Bare Main Replacement Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY