

LOCATION 809 E. Franklin Blvd. CITY CASTOWIA
BETWEEN Second Ave. STREET & Franklin Blvd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>48'</u>	<u>1-10-94</u>	<u>20' Existing</u>	<u>3/4 Plastic</u>
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						


ENTERS: 809 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 600 P.S.I. INCHES W.C. LOCATION 311' S of C of Franklin Blvd.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 3 Ft. 0 In. LOCATION 18' W of C of Chestnut St.

"A" P/S READING P TOTAL ANODES 1* 17* L.R. #

REMARKS:

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY

* Plastic Service has
A Steel Riser.
with Tracer wire