

LOCATION 914 E Franklin Blvd. CITY East.  
BETWEEN Church St. STREET & Dead End STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>RECOVER.</u>		<u>8-</u>	<u>1-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>				
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>				

ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 125' from @ of Church St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY A.F.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997  
DEPTH. 3 FT 5 IN LOCATION S. of KATE St.

"A" P/S READING P. TOTAL ANODES 1# ✓ 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY