

LOCATION 1121 E Franklin Blvd. CITY Gastonia

BETWEEN Patrick St. STREET & Edgemont Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P.	150'			5-21-97
MAIN TO PROP. LINE	"	"	8'			
PROP. LINE TO BLDG.	"	"	142'			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 100' from @ of

Patrick St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DH

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1952

DEPTH: 3 FT. 0 IN. LOCATION SouthSide of Franklin Blvd.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY