

LOCATION 1132 E Franklin BlvdCITY GASTONIABETWEEN Patrick St.STREET & Edgemont Ave.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	?	174'			5-22-97
MAIN TO PROP. LINE	"	"	79'			
PROP. LINE TO BLDG.	"	"	95'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: <u>3/4"</u>	PRESSURE <u>60</u> PSI	INCHES WC	LOCATION <u>102' From (C) OF Patrick St.</u>
-----------------------	------------------------	-----------	--


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DNH

MAIN-SIZE <u>4"</u>	C.I. _____	BARE STEEL _____	COATED STEEL _____	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED <u>1997</u>
---------------------	------------	------------------	--------------------	---	----------------------------

DEPTH: 3 FT. 0 IN LOCATION SOUTH Side of Franklin Blvd.

"A" P/S READING <u>?</u>	TOTAL ANODES 1# <u>-</u> 17# <u>-</u>	L.R. # <u>-</u>
--------------------------	---------------------------------------	-----------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY