

LOCATION 1136 E FRANKLIN BLVD. CITY Gastonia

BETWEEN EDGEmont Ave. STREET & PATRICK St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>53'</u>			<u>5-28-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>23'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>30'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 169' From @ of

EDGEmont Ave.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DHJ.

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION Southside of Franklin Blvd.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY