

LOCATION 1500 E. Franklin CITY Boston  
BETWEEN Beverly STREET & \_\_\_\_\_ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>48'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>0.1</u>	<u>8-23-99</u>		
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>48'</u>			

ENTERS 1500 BRANCHED INTO 0  
TAP SIZE 3/4 IN. PRESSURE 60 PSI \_\_\_\_\_ INCHES WC LOCATION \_\_\_\_\_

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP

MAIN SIZE 3/4 C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH 3 FT 6 IN LOCATION \_\_\_\_\_

"A" P/S READING D TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>0.125</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

