

LOCATION 1817 E. Franklin Blvd CITY GASTONIA  
BETWEEN West Club Cir STREET & Ridge STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	118'	12-4-97	3/4" G.W. to be	
MAIN TO PROP. LINE	3/4"	P	60'		Retired with	
PROP. LINE TO BLDG.	3/4"	P	58'		main.	

ENTERS: Same BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 25' East of West Club Cir

152' South of E. Franklin Blvd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY B. Ballard

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 6 IN LOCATION 25' East of West Club Cir

"A" P/S READING Plastic TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Retired & Renewed Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	<u>Retire</u>
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY