

LOCATION 2224 E. Franklin Blv. CITY Gastonia  
 BETWEEN Glennwood Rd. STREET & Club Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
<del>MAIN</del> TO BLDG	<u>3/4"</u>	<u>P</u>	<u>68'</u>	<u>4-6-01</u>		
<del>MAIN</del> TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>23'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>	<u>"</u>		

ENTERS 2224 BRANCHED INTO 2344  
 TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 182' West


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody  
center of Glennwood Rd.

PIPE SIZE 3/4" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 2001

DEPTH 1' FT 18" IN LOCATION 214' north of center of E. FRANKLIN Blv.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 0254901

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riiser</u>