

LOCATION 2475 E. Franklin Blv CITY Gastonia
BETWEEN Cox Rd STREET & — STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>195'</u>	<u>6-27-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>90'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>105'</u>			

ENTERS: 2475 E. Franklin Blv. BRANCHED INTO: ⊙
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY J.C.
MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1964
DEPTH: 2 FT. 6 IN LOCATION

"A" P/S READING .6 TOTAL ANODES 1# _____ 17# 1 L.R. # 0312943

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY