

LOCATION 2840 E. Franklin BlvdCITY GastoniaBETWEEN Home depot Dr.STREET & Don Pablo's Dr

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	358'	10-14-97		
MAIN TO PROP. LINE	11	11	0			
PROP. LINE TO BLDG.	11	11	358'			

ENTERS: 2840BRANCHED INTO: 0TAP SIZE: 3/4PRESSURE 60 PSI

INCHES W.C.

LOCATION 10' E of c of
Don Pablo's DrPRESSURE TEST: @ 160 PSI FOR 1/4 HRS BY BCMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997DEPTH. 3 FT IN LOCATION 52' S of c of Home depot Dr."A" P/S READING plasticTOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY