

LOCATION 2850 E. Franklin Bl. CITY Coastal

BETWEEN Cox Rd. STREET & STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------------|----------|-----------|----------------|---------|---------|
| MAIN TO BLDG | <u>3/4</u> | <u>P</u> | <u>25</u> | <u>8-11-99</u> | | |
| MAIN TO PROP LINE | <u>3/4</u> | <u>P</u> | <u>0</u> | | | |
| PROP LINE TO BLDG | <u>3/4</u> | <u>P</u> | <u>25</u> | | | |

ENTERS 2850 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI INCHES WC LOCATION


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY LED

MAIN-SIZE 2 1/2 C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH 2 FT 6 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17 LR #

REMARKS



| Test Station | | |
|---------------------------------------|----------|------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead Red New Service | <u>S</u> | <u>0.1</u> |
| P/S Pipeline Lead White Existing Main | <u>E</u> | <u>0.1</u> |