

LOCATION 3638 E. Franklin Blvd. (GATORS) CITY GASTONIA  
BETWEEN Cox Rd. STREET & Church St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	8'	8-25-98		
MAIN TO PROP. LINE	3/4"	P	0			
PROP. LINE TO BLDG.	3/4"	P	8'			


ENTERS: 3638 BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI          INCHES W C LOCATION 51' W. of center of  
Driveway

PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. HURPOLLER  
MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 5 FT 0 IN LOCATION 23' S. of center of Driveway

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 2019072

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY