

LOCATION 3692 E. Franklin Blvd.CITY GastoniaBETWEEN Church StSTREET & Cox Rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PL</u>	<u>60'</u>	<u>3-30-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PL</u>	<u>0</u>	<u>3-30-98</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PL</u>	<u>60'</u>	<u>3-30-98</u>		

ENTERS: SAME

BRANCHED INTO:


TAP SIZE: 3/4PRESSURE 60

PSI

INCHES W.C.

LOCATION 28' East of West CornerOF BuildingPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY T. LomanMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 1998DEPTH: 3 FT. IN. LOCATION 60' North of Back of Building"A" P/S READING TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY