

LOCATION <u>3725 E. Franklin Blvd. Hesters</u>		CITY <u>GASTONIA</u>	
BETWEEN <u>Church St.</u>		STREET & <u>Cox Rd.</u>	
	SIZE	TYPE	LENGTH
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>148'</u>
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>5'</u>
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>143'</u>
ENTERS <u>3725</u>		BRANCHED INTO <u>0</u>	
TAP SIZE <u>1/2</u>	PRESSURE <u>60</u> PSI	INCHES W.C. LOCATION <u>328' W. of Cox Church St.</u>	
PRESSURE TEST <u>100</u> PSI FOR <u>1/4</u> HRS BY <u>RL</u>			
MAIN SIZE <u>2 1/2</u>	C.I.	BARE STEEL	COATED STEEL
DEPTH <u>3</u> FT <u>6</u> IN			PLASTIC <u>✓</u>
YEAR INSTALLED <u>1999</u>		LOCATION <u>60' S of Cox E. Franklin Blvd.</u>	
A P/S READING <u>N/A PLASTIC</u>		TOTAL ANODES 1# <u>0</u> 17# <u>0</u> LR # <u>065098</u>	
REMARKS			
<u>* New Service</u>			

Test Station		
Reading & Location	Lead	Notes
P/S Pipe Line Lead - Red	S	<u>Diser</u> <u>PLASTIC</u>
New - gage		
P/S Pipe Line Lead White	E	
Exisist - main		

COPY