

LOCATION 3735 E. Franklin Blvd CITY GASTONIA

BETWEEN Church St STREET & Cox Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>178'</u>	<u>1-19-99</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>168'</u>			

ENTERS: 3735 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 122' W. of center of

Church St.


PRESSURE TEST: @ 100 PSI FOR 4 HRS BY S. Hufferoth

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH: 3 FT 0 IN LOCATION 45' S. of center of E. Franklin Blvd

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 35014

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY