

LOCATION 3736 E. Franklin St. CITY GASTON, N.C.

BETWEEN Church St. STREET @ Cox Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>69'</u>	<u>2-11-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>69'</u>			

ENTERS: 3786 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P S I INCHES W C LOCATION 70' E of Back of Building


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S.A.

MAIN - SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 4 Ft. 0 In. LOCATION 150' N of center of Driveway

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 69956

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	