

LOCATION 3750 E. Franklin Blvd. CITY Gastonia

BETWEEN Church St. STREET & Cox Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	34'	12-28-98		
MAIN TO PROP. LINE	3/4"	P	0			
PROP. LINE TO BLDG.	3/4"	P	34'			

ENTERS: 3750 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES WC LOCATION 101' S. of ~~corner~~ corner of Building


PRESSURE TEST: @ 100 PSI FOR 44 HRS BY S. Huffstetter

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 3 FT 0 IN LOCATION 35' off Back of Building

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 2324319

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY