

LOCATION 425 W. FRANKLIN BLV. CITY Castroville  
BETWEEN Whiteside STREET & Chesler STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>14'</u>	<u>Relocated</u>	<u>10-29-96</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 425 BRANCHED INTO: 0

TAP SIZE: 3/4 Sec. PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY ED

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH: 1 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17#0 L.R. # \_\_\_\_\_

REMARKS:

Tracer wire from Riser bonded to Ext C/W pipe

	Test Station		ENG. DEPT. USE ONLY
	Reading & Location	Lead	
	P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.2</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

