

LOCATION 1330 W FRANKLIN BLVD. CITY GASTONIA  
 BETWEEN LINWOOD RD STREET & LANCE ST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>40'</u>	<u>11-17-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>25'</u>			


ENTERS 1550 W FRANKLIN BLVD BRANCHED INTO 1330 & 1342  
 TAP SIZE 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 180' E OF C DE  
LINWOOD RD

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RR  
 SIZE 3/4 C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC S YEAR INSTALLED 1992

DEPTH 1 FT 5 IN LOCATION 160' N OF C DE W. FRANKLIN BLVD

"A" P/S READING Plastic TOTAL ANODES I# 0 17# 0 LR # 01067019

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>Riser</u>