

LOCATION 1850 W. Franklin Blvd. CITY Easton  
BETWEEN Washington St. STREET & Bennett City Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>106'</u>	<u>3-16-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>101'</u>			

ENTERS: 1850 BRANCHED INTO: 0

TAP SIZE. 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 233' W of Cor Washington St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE-STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 FT 6 IN LOCATION \_\_\_\_\_

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 172246

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY