

LOCATION 1900 W. Franklin Blvd. CITY GASTONIA

BETWEEN Bessmer City Rd. STREET & Deble St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>225'</u>	<u>5-9-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>210'</u>			

ENTERS 1900 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 293' W. of park at Bessmer City Rd.


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S. G.

MAIN-SIZE C I BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1963

DEPTH 3 FT 0 IN LOCATION 33" N. of park at Franklin Blvd.

"A" P/S READING 1.3 TOTAL ANODES 1# 8 17# 0 LR # 344440

REMARKS New 3/4" p. service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	riser