

LOCATION 2105 W. Franklin Blvd CITY Gastonia  
BETWEEN Garrison STREET & Packard STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>314</u>	<u>P</u>	<u>119'</u>	<u>10-9-96</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>79</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>40</u>			

ENTERS: 2105 BRANCHED INTO: 0  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 181' W of Garrison

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY BC  
MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996  
DEPTH: 3 FT. \_\_\_\_\_ IN. LOCATION 34' N of C of W. Franklin

"A" P/S READING plastic TOTAL ANODES 1# - 17# - L.R. # 567515

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY