

LOCATION 2740 W-FRANKLIN BLVD. CITY SANTONIA
BETWEEN TRAKAN BLVD. STREET & SHANNON BRADLEY RD. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>61'</u>	<u>9-2-00</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>0'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>61'</u>			

ENTERS 2740 BRANCHED INTO: 0

TAP SIZE: 3/4 PRESSURE 40 PSI INCHES W.C. LOCATION 620' N of Caf W. Frank Blvd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL


MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH. 3 FT 6 IN LOCATION 16' E of Caf Entrance to Bynlan Corp.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR #

REMARKS

* Access Rd. Not Named yet.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>Plastic</u>

COPY