

LOCATION 3032 W. FRANKLIN Blvd CITY Gastonia  
BETWEEN TRAKAS Blvd STREET & Shannon Bradley STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	107'	12-16-94		
MAIN TO PROP. LINE	11	11	30'			
PROP. LINE TO BLDG.	11	11	77'			


ENTERS: 3032 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W C LOCATION 13' N. of cor  
 Hwy 74

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP  
MAIN-SIZE 6" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1965

DEPTH: 2 FT 6 IN. LOCATION \_\_\_\_\_

"A" P/S READING 900 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>AE</u>	

ENG. DEPT. USE ONLY