


LOCATION	440-A Freedom Mill Rd			CITY	Spartanburg	
BETWEEN	Aspen		STREET & Chestnut		STREET	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	115	1-25-94		
MAIN TO PROP. LINE	3/4	"	15			
PROP. LINE TO BLDG.	3/4	"	100			

ENTERS: 440-A		BRANCHED INTO:	
TAP SIZE: 7/8	PRESSURE _____ P.S.I.	INCHES W.C.	LOCATION: Side of house

PRESSURE TEST: @ 100 psi For 14 Hrs. By Bennett			
MAIN-SIZE 6	C.I. _____	BARE STEEL _____	COATED STEEL _____ PLASTIC _____
YEAR INSTALLED 1984			
DEPTH: 2 Ft. 6 In.		LOCATION 15810 St	

"A" P/S READING 1.70	TOTAL ANODES 1# _____ 17# _____	L.R. # 00024524
----------------------	---------------------------------	-----------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY