

LOCATION 1229 Freedom Mill Rd. CITY GAstonia
BETWEEN Stone Hedge Dr. STREET & Lewis Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>PLASTIC</u>	<u>100'</u>	<u>9-30-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>PLASTIC</u>	<u>12'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>PLASTIC</u>	<u>88'</u>			

ENTERS 1229 BRANCHED INTO 0
TAP SIZE 3/8" PRESSURE 60 PSI INCHES W C LOCATION 143' N of C of Stone Hedge Dr.


PRESSURE TEST @ 100 PSI FOR 44 HRS BY RL

MAIN SIZE 6" C I BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1985

DEPTH 4 FT 0 IN LOCATION 19' E of C of Freedom Mill Rd.

"A" P/S READING 11.1 TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Trace</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>PLASTIC</u>