

LOCATION 2916 FReIDA LN

CITY Gastonia

BETWEEN Fonda

STREET & Dead end.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED.
MAIN TO BLDG.	3/4	P	49'	Replaced		
MAIN TO PROP. LINE				4-4-95		
PROP. LINE TO BLDG.						

ENTERS: 2916 BRANCHED INTO: 0

TAP SIZE: 3/4" SW. PRESSURE 60 P.S.I. INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 4 Hrs. By EP

MAIN-SIZE 3/4" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1971

DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING 1.3 TOTAL ANODES 1# 17# 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S Riser	Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY