

LOCATION 1926 Fuller Dr. CITY GASTONIA
BETWEEN Echo Lane STREET & Fuller Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>74'</u>	<u>12-15-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>72'</u>			

ENTERS: 1926 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 100 P.S.I. INCHES W.C. LOCATION 79' E of C of Fuller Dr.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AL
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1965
DEPTH: 3 Ft. 0 In. LOCATION 24' S of C of Belmar Dr.

"A" P/S READING 1.0 TOTAL ANODES 1* 17* L.R. # 564482

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic N/A
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY