

LOCATION 2825 GAIL Ave CITY GASTONIA

BETWEEN LYON STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>94'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>60'</u>		<u>3-2-98</u>	
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>34'</u>			

ENTERS: 2831 BRANCHED INTO 2825

TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W C LOCATION


PRESSURE TEST @ 100 PSI FOR 14 HRS BY ED

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1965

DEPTH: 1 FT 6 IN LOCATION _____

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY