

LOCATION 5620 GALLAGHER DR CITY Gastonia
BETWEEN Superior Stainless STREET & Road end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	170'	7-8-98		
MAIN TO PROP. LINE	1"	1	17'			
PROP. LINE TO BLDG.	1"	1"	153			

ENTERS: 5620 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 12' E. of Cop
Gallagher


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY JP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1989

DEPTH: 2 FT. 6 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		