

LOCATION 5644 GALLAGHER DR CITY CASTONIA  
BETWEEN Bermantown Rd STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	142'	12/9/95		
MAIN TO PROP. LINE	3/4"		40'			
PROP. LINE TO BLDG.	3/4"		102'			

ENTERS: 5644 BRANCHED INTO:  
TAP SIZE: 3/8" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION South side of 5644

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DJ  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1981  
DEPTH: 2 Ft. 6 In. LOCATION East side of GALLAGHER DR.

"A" P/S READING 1.20 TOTAL ANODES 1\* 0 17\* 0 L.R. # 618435

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY