

LOCATION 115 Gamble Loop Rd. CITY GASTON, N.C.  
BETWEEN Hwy 24-74 STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED <u>Relocated</u>
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>48'</u>			<u>4-29-02</u>
MAIN TO PROP LINE						
PROP LINE TO BLDG						

ENTERS 115 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W/C LOCATION

PRESSURE TEST @ 100 PSI FOR 48 HRS BY S.H.  
MAIN-SIZE 3/4" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED \_\_\_\_\_  
DEPTH 2 FT A LOCATION

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

