

LOCATION 2424 Gardner St. CITY Gastonia
BETWEEN Bush St. STREET & Myers St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>35'</u>	<u>3-1-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>25'</u>			

ENTERS: 2437 BRANCHED INTO: 2424
TAP SIZE: 3/4 straight p. tee PRESSURE 60 P.S.I. INCHES W.C. LOCATION 345' S of C of Bush St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

Service MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 2 Ft. 0 In. LOCATION 46' E of C of Gardner St.

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. # 073565

REMARKS: 3/4 Split Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY