

LOCATION 2508 Gardner St. CITY BASTONIA  
BETWEEN Bush St. STREET & Myers St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>86'</u>	<u>10-15-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>36'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>50'</u>			


ENTERS: 2502 Gardner St. BRANCHED INTO: 2508 Gardner St.  
TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 454' N of C of Myers St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL  
SERVICE SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1959

DEPTH: 2 FT. 0 IN. LOCATION 88' E of C of Gardner St.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 586859

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY