

LOCATION 2519 Gardner st CITY Gastonia

BETWEEN Myers STREET & Kennedy STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>64</u>	<u>12-2-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>34</u>			

ENTERS: 2519 BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 275' N of C of Myers


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BC

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT IN. LOCATION 13' E of C of Gardner st

"A" P/S READING Plastic TOTAL ANODES 1# - 17# - L.R. # 676226

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>AR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY