

LOCATION 3025 Gardner Park Dr.CITY CamdenBETWEEN BridlepathSTREET & Derby Ct


STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>1'</u>	<u>4-23-94</u>	<u>Tied over</u>	<u>165' OP</u>
MAIN TO PROP. LINE					<u>3/4" G.W. Service</u>	<u>TO EXT</u>
PROP. LINE TO BLDG.					<u>4" Plastic Main</u>	

ENTERS: 3025BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 600 P.S.I. _____ INCHES W.C. LOCATIONPRESSURE TEST: @ 100 psi For 14 Hrs. By EPMAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993DEPTH: 3 Ft. 6 In. LOCATION"A" P/S READING P TOTAL ANODES 1* 1 17* _____ L.R. # _____

REMARKS:

Bonded Insulated Glass
Trace wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>1.3</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY