


LOCATION 3039 + (3101) Gardner Park Dr. CITY GASTONIABETWEEN Bridle Path STREET & Eastwood STREET:

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED ^{TIED OVER} | RENEWED |
|---------------------|---------------|------------|------------|---|---|---------|
| MAIN TO BLDG. | <u>3 1/4"</u> | <u>ctw</u> | <u>-0-</u> | <u>TIED OVER 4-23-99 (3101)</u> <u>145' 3 1/4"</u> | | |
| MAIN TO PROP. LINE | | | | <u>ctw 2-20-80</u> | <u>33' 3 1/4"</u> <u>ctw</u> | |
| PROP. LINE TO BLDG. | | | | | | |

ENTERS: 3039 BRANCHED INTO: -TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 18' south of
Gardner ParkPRESSURE TEST: @ 100 psi For 14 Hrs. By M ParkerMAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 93DEPTH: 3 Ft. 0 In. LOCATION 78' East of Bridle Path"A" P/S READING .95 TOTAL ANODES 1* 1 17* _____ L.R. # _____

REMARKS:



| Test Station | | |
|--|------|--------------------------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | <u>ctw Riser</u> <u>.95</u> |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY