

LOCATION 3131 Gardner Park DriveCITY GASTONIA

BETWEEN

CheswickSTREET & Eastwood

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>cu</u>	<u>- 0 -</u>	<u>TIED OVER</u> <u>4-23-91</u>		
MAIN TO PROP. LINE				<u>149' 3/4" cu</u>		
PROP. LINE TO BLDG.				<u>11-12-82</u>		

ENTERS: 3131

BRANCHED INTO:

TAP SIZE: <u>1/2</u>	PRESSURE <u>60</u> P.S.I. _____ INCHES W.C.	LOCATION <u>18' S OF Gardner</u> <u>Park</u>
----------------------	---	---


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Prokes

MAIN-SIZE <u>4"</u>	C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC <u>X</u>	YEAR INSTALLED <u>93</u>
---------------------	---	--------------------------

DEPTH: 3 Ft. 0 In. LOCATION 17' W OF Eastwood

"A" P/S READING <u>1.0</u>	TOTAL ANODES 1# <u>1</u> 17# _____	L.R. # _____
----------------------------	------------------------------------	--------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>160 cu RISE</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY