

LOCATION 3231 Gardner PARK Dr. CITY GASTONIA  
BETWEEN Holiday St. STREET & Rosemary Lane STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>110'</u>	<u>1-13-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>95'</u>			

ENTERS: 3231 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 167' w of C of Holiday St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1962

DEPTH: 3 Ft. 0 In. LOCATION 11' S of C of Gardner PARK Dr.

"A" P/S READING 1.0 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY