

LOCATION 1804 Garland Ave. CITY GASTONIA
BETWEEN Belmar Dr. STREET & Sharon Lane. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>	<u>8-13-94</u>	<u>Tied over</u>	<u>95' Existing</u>
MAIN TO PROP. LINE					<u>3/4 CFW</u>	<u>Pipe</u>
PROP. LINE TO BLDG.						


ENTERS: 1804 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 270' E of Sharon Lane.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993
DEPTH: 3 Ft. 0 In. LOCATION 14' S of C of Garland Ave.

"A" P/S READING Plastic TOTAL ANODES 1# 1 17# L.R. # 350971

REMARKS: Tied Tracer wire OFF At Tee. Found Ins. Dresser, Bonded + Shot 1# Anode on Service line

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u> <u>.85</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY