

LOCATION 1812 Garland AveCITY GASTONIABETWEEN SHARON LaneSTREET & BELMAN Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>2'</u>	<u>8-13-94</u>	<u>Tied over 156' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 CTW</u>	
PROP. LINE TO BLDG.						

ENTERS: 1812BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION 188' E. of C of Garland Ave.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 2"


C.I.

BARE STEEL

COATED STEEL

PLASTIC ☒YEAR INSTALLED 1993DEPTH: 3

Ft.

0 In.LOCATION 14' S of C of Garland Ave."A" P/S READING PLASTICTOTAL ANODES 1* 17 *L.R. # 350971REMARKS: Tied Trace Wire OFF At Top.Bare Main Replacement
Program

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser 1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY