


LOCATION 2205 + 2207 Garland AveCITY GASTONIABETWEEN American St. STREET & DAVIS Park Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>		<u>10/25/99</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 2205 BRANCHED INTO: 2207

TAP SIZE: \_\_\_\_\_ PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ \_\_\_\_\_ PSI FOR \_\_\_\_\_ HRS BY \_\_\_\_\_

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1970DEPTH: 2 FT 0 IN. LOCATION \_\_\_\_\_"A" P/S READING 1.100 TOTAL ANODES 1# \_\_\_\_\_ 17# 5 L.R. # \_\_\_\_\_REMARKS: Bonded 7/5

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Risers</u>	<u>1.050</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY

tt th  
- 2205 + 2207