

LOCATION 128 E. GARRISON Blvd CITY GAZTOWN
BETWEEN S. MARSHALL ST STREET & S. OAKLAND STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	133'	5-13-96		
MAIN TO PROP. LINE	3/4"	P	0			
PROP. LINE TO BLDG.	3/4"	P	133'			

ENTERS: 125 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 600 PSI INCHES W.C. LOCATION 276' W. of center of S. OAKLAND ST

PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY S. HUFFGUTH
~~MAIN~~ SIZE 3/4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED
DEPTH: FT. IN. LOCATION 188' N. of center of E. GARRISON Blvd.

"A" P/S READING 1.1 TOTAL ANODES 1# 17# L.R. # 239716

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY