

LOCATION 330 E. Garrison Blvd.CITY Easton, PaBETWEEN Union Rd.STREET & Oakland

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>90'</u>	<u>3-15-54</u>	<u>Tied over</u>	<u>150' of EXT 3/4</u>
MAIN TO PROP. LINE					<u>plastic to EXT 2" plastic</u>	
PROP. LINE TO BLDG.					<u>main</u>	

ENTERS: 330 GarrisonBRANCHED INTO: 6TAP SIZE: 1/2PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EAMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_DEPTH: 3 Ft. 6 In. LOCATION"A" P/S READING P TOTAL ANODES 1\* — 17\* — L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY