

LOCATION 438 E. GARRISON BLVD CITY Castroville
BETWEEN UNION RD. STREET & OAK STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>36'</u>		<u>Tied over</u>	<u>40' of 1/2"</u>
MAIN TO PROP. LINE				<u>7-20-95</u>	<u>3/4 Plastic</u>	<u>to 3/4 Plastic</u>
PROP. LINE TO BLDG.	<u>WICHITA</u>				<u>Sec. in # 430 E. GARRISON</u>	

ENTERS: 430 BRANCHED INTO: 438
TAP SIZE: 3/4 PRESSURE 60 P.S.I. 3.02 INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 14 Hrs. By EP

MAIN SIZE 3/4 C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 2 Ft. 6 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY